



Certificate of Conformity

By the product certificate number

Issued to

License holder

Shenzhen Atess Power Technology Co., Ltd 1st Floor of Building 3 at Sector B and 3rd Floor or Building 9, Henglong Industrial Park, Shuitian, Baoan District, Shenzhen, Guangdong Province, P.R. China

Trademark

Manufacturer



Shenzhen Atess Power Technology Co., Ltd 1st Floor of Building 3 at Sector B and 3rd Floor or Building 9, Henglong Industrial Park, Shuitian, Baoan District, Shenzhen, Guangdong Province, P.R. China No: 2620/0202-CER



It is certified that the product:

| Type of generator | Hybrid Inverter | |
|-------------------|-----------------|--|
| | | |

| Models | | HPS100 | HPS120 | HPS150 |
|----------------|-----------------------|-------------------|---|------------------|
| Technical Data | Rated Active Power | 100 kW | 120 kW | 150 kW |
| | Rated Voltage | | 400 V | |
| | Rated Frequency | | 50 Hz | |
| | Firmware version | | DSP: HV3-SV4.1.09 / LCD: HV1.0-SV1.0.4 | |
| 000 | Number of phases | | Three phases (3P/PE) | |
| | Isolation transformer | | NO | |
| | | (See further info | ormation about rating characteristic | s in the page 2) |

Is in compliance with

Regulation

EN 50549-1: 2019

Requirements for generating plants to be connected in parallel with distribution networks – Part 1: Connection to a LV Distribution Network - Generating Plants up to and including type B.

This certificate just covers PV inverters models certified below above-mentioned references to be installed in PV generating of type plants B to be connected to a LV distribution network.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-53 based on the requirements of the UNE-EN ISO / IEC 17065

This certificate is valid until: 19th of June 2023. First issued on: 19th of June 2020.

Madrid, 19th June 2020

Daniel Arranz Muñiz Certification Manager



SGS Tecnos, S.A. C/ Trespaderne, 29 - 28042 Madrid This certificate is issued by SGS under its General Conditions for Product Certification at <u>www.sgs.com/terms_and_conditions</u>. The status and validity of the certificate can be checked scanning the QR code above included or through the following web link database: https://www.sgs.com/en/certified-clients-and-products/electrical-products/

This document cannot be reproduced partially



Full list of rated characteristics of certified models:

| Model Number | HPS100 | HPS120 | HPS150 | |
|---------------------------------|--------------------------------|---------|---------|--|
| PV parameters | | | • | |
| PV rated Power | 110 kW | 132 kW | 165 kW | |
| Max. PV Power | 150 kW | 180 kW | 225 kW | |
| Max. PV input voltage | 1000 Vd.c. | | | |
| PV MPPT voltage range | 480-800 Vd.c. | | | |
| Battery parameters | | | | |
| Battery operating voltage range | 352-600 Vd.c. | | | |
| Max.Battery charge current | 300 A | 350 A | 450 A | |
| Max.Battery discharge current | 313 A | 374 A | 467 A | |
| Max.Battery charge power | 150 kW | 180 kW | 225 kW | |
| Max.Battery discharge power | 110 kW | 132 kW | 165 kW | |
| AC output parameter | | | | |
| Rated voltage | 400 Vac | | | |
| Rated current | 144 A | 173 A | 217 A | |
| Rated output power | 100 kW | 120 kW | 150 kW | |
| Rated frequency | 50 Hz | | | |
| Frequency Range | 45-55 Hz | | | |
| Max.output power | 110 kVA | 132 kVA | 165 kVA | |
| Max. input power | 200 kVA | 240 kVA | 240 kVA | |
| Power factor | 1 default (+/- 0.8 adjustable) | | | |
| Ambient temperature | -25 °C ~ 55 °C | | | |
| Ingress protection | IP20 | | | |
| Protective class | Class I | | | |



SGS Tecnos, S.A. C/ Trespademe, 29 - 28042 Madrid This certificate is issued by SGS under its General Conditions for Product Certification at <u>www.sgs.com/terms_and_conditions</u>. The status and validity of the certificate can be checked scanning the QR code above included or through the following web link database: <u>https://www.sgs.com/en/certified-clients-and-products/electrical-products</u>. This document cannot be reproduced partially

SGSSG

Nº 2620/0202-CER Page 2 of 2